

1. Unique identification code of the product-type:

**Integrierter Schließfolgeregler ECO SRI**

2. Purpose of application or purposes of application intended by the manufacturer of the construction product in accordance with the applicable harmonised technical specification:

**To ensure correct closing sequence of double-leafed doors for fire/smoke resistance closures**

3. Name, registered brand name or registered brand and contact address of the manufacturer in accordance with Article 11, Paragraph 5:

**ECO Schulte GmbH & Co. KG  
Iserlohner Landstraße 89  
D-58706 Menden**

4. If appropriate, name and contact address of the authorised representative who is assigned to the tasks in accordance with Article 12, Paragraph 2:

**N/A**

5. Harmonised standard:

**EN 1158:1997/A1:2002/AC:2006**

6. Notified body:

The notified certification body for in-house production checks **no. 0432** has carried out the initial inspection of the manufacturing plant and factory production checks as well as the continuous monitoring, assessment and evaluation of the factory production checks and has issued the certificate of conformity of factory production checks (**to 0432-CPR-00336-01.1**).

**Notified product certification body no. 0432**

**Declaration of performance**  
**No. DOP-1158-EN3-6-00336-01.1**



7. Declared performance:

| Essential characteristics                            | Performance  | Harmonised technical specification  |
|--|--|-------------------------------------|
| <b>Ability to release</b>                            |  | <b>EN 1158:1997/A1:2002/AC:2006</b> |
| 5.1.2 Completeness of the products                   | Passed   |                                     |
| 5.1.3 Correct closing sequence                       | Size 3-6: Passed   |                                     |
| 5.2.1 General  | Passed   |                                     |
| 5.2.2 Overload behaviour in closing direction        | Size 3-6: Passed   |                                     |
| 5.2.3 Manipulation                                   | Size 3-6: Passed   |                                     |
| 5.2.4 Resistance in waiting position                 | Size 3-6: Passed   |                                     |
| 5.2.6 Damage   | Size 3-6: Passed   |                                     |
| 5.2.8 Suitability for fire- / smoke protection doors | Class 1: For use on fire-/smoke resistance doors acc. to a test of EN 1634-1.          |                                     |
| <b>Durability self-closing</b>                       |  |                                     |
| 5.2.5 Durability                                     | Class 8: 500,000 cycles  |                                     |
| 5.2.7.1 Corrosion resistance                         | Class 0: no requirements   |                                     |
| 5.2.7.2 Corrosion resistance                         | Class 0: no requirements   |                                     |
| 5.2.7.3 Corrosion resistance                         | Class 0: no requirements   |                                     |
| <b>Dangerous substances</b>                          |  |                                     |
| ZA.3 Dangerous substances                            | The materials used in this product do not contain or release any dangerous substances. |                                     |

**Declaration of performance**  
**No. DOP-1158-EN3-6-00336-01.1**



8. Suitable technical specification and/or technical documentation:

**N/A**

The performance of the above products complies with the declared performance/the declared performances. The manufacturer mentioned above is solely responsible for drawing up the declaration of performance in accordance with Regulation (EU) no. 305/2011.

Tobias Schulte, Managing Director of ECO Schulte GmbH & Co. KG  
(Name of the signatory and function in the company)

Menden, 02.10.2023  
(Place and date of issue)

A handwritten signature in black ink, appearing to read "T. Schulte", written over a light grey rectangular background.

\_\_\_\_\_  
(Signature)