

**Materialprüfungsamt Nordrhein-Westfalen**

Prüfen · Überwachen · Zertifizieren

**Certificate of constancy of performance****0432-CPR-00099-11**

Version 04

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

**ECO Door Hinges Ø 18 mm roll length 120 mm**

Uniaxial door hinges as detailed and classified on annex 1

placed on the market under the name or trade mark of

**ECO Schulte GmbH & Co. KG**Iserlohner Landstraße 89  
58706 Menden, Germany

and produced in the manufacturing plant(s)

**DO 25.21**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in annex ZA of the standard(s)

**EN 1935:2002/AC:2003**

under **system 1** for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

**constancy of performance of the construction product.**

This certificate was first issued on 08.02.2019 and will remain valid until 08.02.2029 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Dortmund, 08.02.2024



By order

RBA Th. Meinks

Deputy Head of Certification Body Department  
2230

This Certificate consists of 1 page and 1 annex(es).  
This Certificate replaces the Certificate no. 0432-CPR-00099-11 dated  
03.12.2021, Version 03.

The original of this document was issued in German language.  
In case of doubt only the German version is valid.



# Materialprüfungsamt Nordrhein-Westfalen

Prüfen · Überwachen · Zertifizieren

## ECO Door Hinges Ø18 mm, 120 mm

<b>Type:</b>	OBX-18-1531/120
<b>Roll length:</b>	120 mm
<b>Roll diameter:</b>	18 mm
<b>Material thickness:</b>	Frame part 3.5 mm, wing part 3 mm
<b>Material:</b>	1.4301 / 1.0332 zinc-plated / 1.0332 nickel-plated
<b>Installation:</b>	rebated
<b>Classification:</b>	3 7 4 1 1 * 1 11
<b>Manufacturing plant:</b>	DO 25.21

### Intended use:

Essential properties	Sections with requirements in EN 1935:2002/A1:2003	Performance of the product
Self-closing	5.1 Starting measurement of the friction torque 5.2.1 Load deformation 5.2.2 Overload 5.3 Shear strength 5.6 Door hinges for fire- and/or smoke protection doors	Passed Class 11 Passed Class 11 Passed Class 11 Passed Class 11 Passed Class 1
Durability	5.4 Durability operation test 5.8 Door hinge groups with common design characteristics 5.5 Corrosion resistance	Passed Class 11 Same pivot bearing, same roll, diameter, same material thickness *1.4301: Passed Class 4 *1.0332 zinc-plated: Passed Class 4 *1.0332 nickel-plated: Passed Class 2
Dangerous substances	Annex ZA.3	The manufacturer has not declared any dangerous substances.

# Materialprüfungsamt Nordrhein-Westfalen

Prüfen · Überwachen · Zertifizieren

## ECO Door Hinges Ø18 mm, 120 mm

<b>Type:</b>	OBX-18-2541/120 OBN-18-4141/120
<b>Roll length:</b>	120 mm
<b>Roll diameter:</b>	18 mm
<b>Material thickness:</b>	Frame part 3.5 mm, wing part 3 mm
<b>Material:</b>	1.4301 / 1.0332 zinc-plated / 1.0332 nickel-plated
<b>Installation:</b>	flush
<b>Classification:</b>	3 7 4 1 1 * 1 11
<b>Manufacturing plant:</b>	DO 25.21

### Intended use:

Essential properties	Sections with requirements in EN 1935:2002/A1:2003	Performance of the product
Self-closing	5.1 Starting measurement of the friction torque 5.2.1 Load deformation 5.2.2 Overload 5.3 Shear strength 5.6 Door hinges for fire- and/or smoke protection doors	Passed Class 11 Passed Class 11 Passed Class 11 Passed Class 11 Passed Class 1
Durability	5.4 Durability operation test 5.8 Door hinge groups with common design characteristics 5.5 Corrosion resistance	Passed Class 11 Same pivot bearing, same roll diameter, same material thickness *1.4301: Passed Class 4 *1.0332 zinc-plated: Passed Class 4 *1.0332 nickel-plated: Passed Class 2
Dangerous substances	Annex ZA.3	The manufacturer has not declared any dangerous substances.

# Materialprüfungsamt Nordrhein-Westfalen

Prüfen · Überwachen · Zertifizieren

## ECO Door Hinges Ø18 mm, 120 mm

<b>Type:</b>	OBX-18-2229/120
<b>Roll length:</b>	120 mm
<b>Roll diameter:</b>	18 mm
<b>Material thickness:</b>	Frame part 3.5 mm, wing part 3 mm
<b>Material:</b>	1.4301 / 1.0332 zinc-plated / 1.0332 nickel-plated
<b>Installation:</b>	flush
<b>Classification:</b>	2 7 3 1 1 * 0 10
<b>Manufacturing plant:</b>	DO 25.21

### Intended use:

Essential properties	Sections with requirements in EN 1935:2002/A1:2003	Performance of the product
Self-closing	5.1 Starting measurement of the friction torque 5.2.1 Load deformation 5.2.2 Overload 5.3 Shear strength 5.6 Door hinges for fire- and/or smoke protection doors	Passed Class 10 Passed Class 10 Passed Class 10 Passed Class 10 Passed Class 1
Durability	5.4 Durability operation test 5.8 Door hinge groups with common design characteristics 5.5 Corrosion resistance	Passed Class 10 Not applicable *1.4301: Passed Class 4 *1.0332 zinc-plated: Passed Class 4 *1.0332 nickel-plated: Passed Class 2
Dangerous substances	Annex ZA.3	The manufacturer has not declared any dangerous substances.

# Materialprüfungsamt Nordrhein-Westfalen

Prüfen · Überwachen · Zertifizieren

## ECO Door Hinges Ø18 mm, 120 mm

<b>Type:</b>	OBX-18-2128/120
<b>Roll length:</b>	120 mm
<b>Roll diameter:</b>	18 mm
<b>Material thickness:</b>	Frame part 3.5 mm, wing part 3 mm
<b>Material:</b>	1.0332 zinc-plated / 1.0332 nickel-plated
<b>Installation:</b>	flush
<b>Classification:</b>	3 7 4 1 1 * 0 11
<b>Manufacturing plant:</b>	DO 25.21

### Intended use:

Essential properties	Sections with requirements in EN 1935:2002/A1:2003	Performance of the product
Self-closing	5.1 Starting measurement of the friction torque 5.2.1 Load deformation 5.2.2 Overload 5.3 Shear strength 5.6 Door hinges for fire- and/or smoke protection doors	Passed Class 11 Passed Class 11 Passed Class 11 Passed Class 11 Passed Class 1
Durability	5.4 Durability operation test 5.8 Door hinge groups with common design characteristics 5.5 Corrosion resistance	Passed Class 11 Not applicable *1.0332 zinc-plated: Passed Class 4 *1.0332 nickel-plated: Passed Class 2
Dangerous substances	Annex ZA.3	The manufacturer has not declared any dangerous substances.

# Materialprüfungsamt Nordrhein-Westfalen

Prüfen · Überwachen · Zertifizieren

## ECO Door Hinges Ø18 mm, 120 mm

<b>Type:</b>	OBX-18-2128/120
<b>Roll length:</b>	120 mm
<b>Roll diameter:</b>	18 mm
<b>Material thickness:</b>	Frame part 3.5 mm, wing part 3 mm
<b>Material:</b>	1.4301
<b>Installation:</b>	flush
<b>Classification:</b>	4 7 5 1 1 4 0 12
<b>Manufacturing plant:</b>	DO 25.21

### Intended use:

Essential properties	Sections with requirements in EN 1935:2002/A1:2003	Performance of the product
Self-closing	5.1 Starting measurement of the friction torque 5.2.1 Load deformation 5.2.2 Overload 5.3 Shear strength 5.6 Door hinges for fire- and/or smoke protection doors	Passed Class 12 Passed Class 12 Passed Class 12 Passed Class 12 Passed Class 1
Durability	5.4 Durability operation test 5.8 Door hinge groups with common design characteristics 5.5 Corrosion resistance	Passed Class 12 Not applicable 1.4301: Passed Class 4
Dangerous substances	Annex ZA.3	The manufacturer has not declared any dangerous substances.

# Materialprüfungsamt Nordrhein-Westfalen

Prüfen · Überwachen · Zertifizieren

## ECO Door Hinges Ø18 mm, 120 mm

<b>Type:</b>	OBX-18-1531/120 LG OBX-18-1531/120 LG-RC-A OBX-18-1531/120 LG-RC-B OBX-18-1531/120 LG-TZ OBX-18-1531/120 LG RC-A-TZ OBX-18-1531/120 LG RC-B-TZ
<b>Roll length:</b>	120 mm
<b>Roll diameter:</b>	18 mm
<b>Material thickness:</b>	Frame part 3 mm, wing part 3 mm
<b>Material:</b>	1.4301
<b>Installation:</b>	rebated
<b>Classification:</b>	4 7 7 1 1 3 1 14
<b>Manufacturing plant:</b>	DO 25.21
<b>Remarks:</b>	LG= laserwelded; TZ= with reinforcing dowel; RC-A= outer frame part chambers closed, RC-B= middle frame part chamber closed

### Intended use:

Essential properties	Sections with requirements in EN 1935:2002/A1:2003	Performance of the product
Self-closing	5.1 Starting measurement of the friction torque 5.2.1 Load deformation 5.2.2 Overload 5.3 Shear strength 5.6 Door hinges for fire- and/or smoke protection doors	Passed Class 14 Passed Class 14 Passed Class 14 Passed Class 14 Passed Class 1
Durability	5.4 Durability operation test 5.8 Door hinge groups with common design characteristics 5.5 Corrosion resistance	Passed Class 14 Same pivot bearing, same roll diameter, same material thickness Passed Class 3
Dangerous substances	Annex ZA.3	The manufacturer has not declared any dangerous substances.

# Materialprüfungsamt Nordrhein-Westfalen

Prüfen · Überwachen · Zertifizieren

## ECO Door Hinges Ø18 mm, 120 mm

<b>Type:</b>	OBX-18-2541/120-LG OBX-18-2541/120-LG-RC-A OBX-18-2541/120-LG-RC-B OBX-18-2541/120-LG-TZ OBX-18-2541/120-LG RC-A-TZ OBX-18-2541/120-LG RC-B-TZ OBN-18-4141/120-LG OBN-18-4141/120-LG-angled OBN-18-4242/120-LG
<b>Roll length:</b>	120 mm
<b>Roll diameter:</b>	18 mm
<b>Material thickness:</b>	Frame part 3 mm, wing part 3 mm
<b>Material:</b>	1.4301
<b>Installation:</b>	flush
<b>Classification:</b>	4 7 7 1 1 3 1 14
<b>Manufacturing plant:</b>	DO 25.21

### Intended use:

Essential properties	Sections with requirements in EN 1935:2002/A1:2003	Performance of the product
Self-closing	5.1 Starting measurement of the friction torque 5.2.1 Load deformation 5.2.2 Overload 5.3 Shear strength 5.6 Door hinges for fire- and/or smoke protection doors	Passed Class 14 Passed Class 14 Passed Class 14 Passed Class 14 Passed Class 1
Durability	5.4 Durability operation test 5.8 Door hinge groups with common design characteristics 5.5 Corrosion resistance	Passed Class 14 Same pivot bearing, same roll diameter, same material thickness Passed Class 3
Dangerous substances	Annex ZA.3	The manufacturer has not declared any dangerous substances.



# Materialprüfungsamt Nordrhein-Westfalen

Prüfen · Überwachen · Zertifizieren

## ECO Door Hinges Ø18 mm, 120 mm

<b>Type:</b>	OBX-18-1532/120 LG OBX-18-1532/120 LG-RC-A OBX-18-1532/120 LG-RC-B OBX-18-1532/120 LG-TZ OBX-18-1532/120 LG RC-A-TZ OBX-18-1532/120 LG RC-B-TZ
<b>Roll length:</b>	120 mm
<b>Roll diameter:</b>	18 mm
<b>Material thickness:</b>	Frame part 3 mm, wing part 3 mm
<b>Material:</b>	1.4301
<b>Installation:</b>	rebated
<b>Classification:</b>	4 7 7 1 1 3 1 14
<b>Manufacturing plant:</b>	DO 25.21

### Intended use:

Essential properties	Sections with requirements in EN 1935:2002/A1:2003	Performance of the product
Self-closing	5.1 Starting measurement of the friction torque 5.2.1 Load deformation 5.2.2 Overload 5.3 Shear strength 5.6 Door hinges for fire- and/or smoke protection doors	Passed Class 14 Passed Class 14 Passed Class 14 Passed Class 14 Passed Class 1
Durability	5.4 Durability operation test 5.8 Door hinge groups with common design characteristics 5.5 Corrosion resistance	Passed Class 14 Same pivot bearing, same roll diameter, same material thickness Passed Class 3
Dangerous substances	Annex ZA.3	The manufacturer has not declared any dangerous substances.